

07th August, 2026

To
The Listing Department
National Stock Exchange of India Limited
Exchange Plaza, Plot No. C/1,
G-Block, Bandra Kurla Complex,
Mumbai-400051
Symbol: SUMIT

Dear Sir/ Madam,

Sub: Intimation of Disapproval (IOD) received for the society named "Vidyavihar Co-op Housing Society".

Pursuant to Regulation 30 of the SEBI (Listing Obligations and Disclosure Requirements) Regulations, 2015, and any other applicable provisions, we would like to inform you that, We have received the Intimation of Disapproval (IOD) from the Brihanmumbai Municipal Corporation for the society named "Vidyavihar Co-op Housing Society" situated in situated on Harishchandra Yelve Marg, Mahim, Mumbai - 400028 as on 07th August, 2026.

The approximate area for construction and development for the said property is 40,000 square feet. The project will offer a revenue potential of approx. around Rs. 160 Crores.

The IOD is issued for the plan of the Project - Sumit Dridha. The IOD obtained prescribes the no objection for carrying out the work with certain conditions.

The IOD is enclosed herewith.

You are requested to kindly take the same on record.

For Sumit Woods Limited



Rekha Bagda
Company Secretary & Compliance Officer



BRIHANMUMBAI MUNICIPAL CORPORATION

Intimation of Disapproval under Section 346 of the Mumbai Municipal Corporation Act, as amended up to date.

No. P-20986/2024)/G/North/FP/IOD/1/New Dated- 07 August 2026

MEMORANDUM

Municipal Office,
Mumbai

To,

M/s. Sumit Woods Ltd.

B-1101, Express Zone, Diagonally Opp. Oberoi Mall, Western Express Hwy, Malad East, Mumbai - 400097

With reference to your Notice 337 (New) , letter No. 337 dated. 6/3/2024 and the plans, Sections Specifications and description and further particulars and details of your buildings at Redevelopment of proposed building under Regn. 33(7)(5)(c) & 33(7)(22) on property bearing F P No. 26A of TPS III Mahim, situated on Harishchandra Yelve Marg, Mahim, Mumbai – 400 028. locally known as "Vidya Vihar Co-op. Hsg. Society".

26A furnished to me under your letter, dated 6/3/2024. I have to inform you that, I cannot approve of the building or work proposed to be erected or executed, and I therefore hereby formally intimate to you, under Section 346 of the Mumbai Municipal Corporation Act as amended up to-date, my disapproval by reasons thereof :-

A: CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE WORK.

- 1 That the commencement certificate under Section 44/69(1)(a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
- 2 That the builder / developer / owner shall not prepare a "debris management plan" showing the prospective quantum of debris likely to be generated, arrangements for its proper storage at the site, transportation plan of the agency appointed for the same, with numbers and registration numbers of vehicles to be deployed and the final destination where the debris would be unloaded by them and submit the same to the Zonal Executive Engineer of S.W.M. Department and the same shall not be got approved before demolition of existing building or commencing any construction activity.
- 3 That the low lying plot will not be filled up to a reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc. and will not be leveled, rolled, consolidated and sloped towards road side, before starting the work.
- 4 That the specifications for layout / D.O. / or access roads / development of set-back land will not be obtained from E.E. Road (Construction) (City) before starting construction work and the access and setback land will not be developed accordingly including providing street light and S.W.D., the completion certificate will not be obtained from E.E.(R.C.)/E.E.(S.W.D.) of city before submitting

building completion certificate.

- 5 That the registered undertaking and additional copy of plans shall be submitted for agreeing to hand over the setback land and that the ownership of the set-back land will be transferred in the name of the local municipal corporation before the occupancy certificate.
- 6 That a qualified structural engineer shall be appointed and the supervision memo as per relevant regulations will be submitted.
- 7 The regular and sanctioned lines and reservation will be demarcated at the site through the appropriate authorities before applying for the Commencement Certificate (C.C.).
- 8 That the structural design and calculations for the proposed work, accounting for seismic analysis as per relevant codes, along with the soil bearing capacity, will be submitted before requesting the C.C.
- 9 That all sanitary arrangements shall be carried out as per municipal specifications and drainage layouts will be submitted.
- 10 That the NOC from M.B.R & R. Board for plinth CC shall not be submitted.
- 11 That a registered site supervisor will be appointed through the Architect or Structural Engineer.
- 12 That the basement will comply with all rules and regulations, and a registered undertaking regarding its proper use will be submitted.
- 13 That appropriate remarks for ventilation and mechanical light for the basement and habitable floors shall be submitted.
- 14 That a report on the feasibility of the basement from a qualified geologist shall be submitted.
- 15 That structural design and stability certificates for underground water tanks to bear vehicular and fire engine loads shall be submitted before asking for the C.C. above the plinth.
- 16 That the services of a Safety Officer to oversee all safety protocols during and around the construction site shall be hired.
- 17 That all required premiums, deposits, and development charges as per the relevant Acts will be paid.
- 18 That the work will be carried out strictly as per approved plans and in conformity with the regulations in force.
- 19 That the janata insurance policies to cover compensation claims arising out of Workmen's Compensation Act, 1923 will not be taken out and a copy of the same will be submitted before asking C.C. and renewed during the construction of work and owner / developer should submit revalidated Janata Insurance Policy from time to time.
- 20 That the Third party insurance shall not be submitted.
- 21 That the plot boundary shall not be got demarcated from C.S.L.R. and demarcation certificate shall not be submitted to this office before asking for C.C.
- 22 That the demarcation of Road Line and Set-back area shall not be submitted before C.C.
- 23 That the fresh Tax Clearance Certificate from A.A.& C. 'G/North' Ward shall not be submitted.
- 24 That the Extra Water Charges & Extra Sewerage Charges shall not be paid / All Dues Clearance Certificate from A.E.W.W. G/N Ward shall not be submitted before Issue/ Endorsement of C.C.
- 25 That the C.C. shall not be asked unless advance payment for providing treatment at construction site

to prevent epidemics like Dengue, Malaria, etc. is made to the Insecticide Officer of the concerned Ward Office and provision shall be made as and when required by Insecticide Officer for Inspection of water tanks by providing safe and stable ladder, etc. and requirements as communicated by the Insecticide Officer shall be complied with.

- 26 That the precautionary measures to avoid dust nuisance such as erection of G.I. sheet screens at plot boundaries upto reasonable height shall not be provided before demolition of existing structures at site.
- 27 That the footpath in front of plot shall not be repaired / restored once in a year or before occupation whichever is earlier.
- 28 That the board displaying the details of proposed work, Name of Owner, Developer, Architect, R.C.C. consultant etc. shall not be exhibited on site.
- 29 That the copy of PAN card of the applicant shall not be submitted before asking for C.C.
- 30 That the work shall not be carried out between 6.00 A.M. to 10.00 P.M. only in accordance with rule 5A (3) of the noise pollution (Reg. & control) Rules 2000 & the provision of notification issued by the ministry of Environment & forest Deptt. from time shall not be duly observed.
- 31 That the construction activity for work of necessary piling shall not be carried out by employing modern techniques such as rotary drilling, micro-piling etc. instead of conventional jack and hammer to avoid nuisance damage to adjoining buildings.
- 32 That the dry & wet waste garbage shall not be separated and the wet garbage generated in the building shall not be treated separately on the same plot by the residents / occupants of the building jurisdiction of MCGM. The necessary condition in the Sale Agreement to the effect shall not be incorporated by the Owner / Developer.
- 33 That undertaking cum indemnity bond from owner stating that they have not received any notice from ULC Authority for handing over / acquiring the land under reference to ULC authority under any section of ULC&R Act shall not be submitted.
- 34 That the registered undertaking from owner stating that they shall not claim any FSI of the encroached portion of the plot at any stage shall not be submitted
- 35 That the conditions of Parking N.O.C. shall not be complied with.
- 36 That following N.O.C. shall not be submitted before asking for C.C.: i) N.O.C. from Dy. Ch. E.(S.P.) P&D/Consultant for proposed sewer line; ii) N.O.C. from B.E.S.T.; iii) N.O.C. from Collector of Mumbai for excavation; iv) N.O.C. from Tree Authority/ Consultant shall not be submitted before asking for plinth C.C.; v) N.O.C. from A.E. (Maint.) G/N Ward for Carriageway Entrance.
- 37 That remarks shall not be submitted: i) Remarks from H.E. Department; ii) Remarks for construction of SWD will not be obtained from Dy. Ch. Eng. (S.W.D.) City / consultant before. iii) Remarks regarding formation level from Road Department.
- 38 No main beam in a R.C.C. framed structure shall not be less than 230 mm wide. The size of the columns shall also not be governed as per the applicable I.S. codes.
- 39 All the cantilevers (Projections) shall not be designed for five times the load as per IS Code 1993-2002 including the columns projecting beyond the terrace and carrying the overhead water storage tank, etc.
- 40 In R.C.C. framed structures, the external walls shall not be less than 230 mm if in brick masonry or

No. P-20986/2024)/G/North/FP/IOD/1/New Dated- 07 August 2026

150 mm. autoclaved cellular concrete block excluding plaster thickness as circulated under No. CE/PD/11945/I of 2.2.2006.

- 41 That the specification & design of Rain Water Harvesting scheme as per the State Govt.'s directives u/No.TPB-4307/396/CR-124/2007/UD-11 dated 6th June 2007 shall not be submitted.
- 42 That the requisition of Regn. 49 of DCPR 2034 shall not be complied with and records of quality of work, verification of report shall not be kept on site till completion of work.
- 43 That the bore well shall not be constructed in consultation with H.E.
- 44 That all the structural members below the ground shall not be designed considering the effect of chlorinated water, Sulphur water, seepage water, etc. and any other possible chemical effect and due care while constructing the same will not be taken and completion certificate to that effect shall not be submitted before granting C.C.
- 45 That the conditions and directions specified in the order of Hon. Supreme Court dated 15-03-2018 in Dumping Ground case shall not be complied with.
- 46 That adequate safeguards shall be employed in consultation with SWM Dept. of M.C.G.M. for preventing disposal of particles through air and the construction debris generated shall be deposited in specific sites inspected and approved by M.C.G.M.
- 47 That the debris shall be managed in accordance with the provisions of Construction and Demolition Waste Management Rules 2016 and requisite Bank Guarantee as deemed by M.C.G.M. for faithful compliance of Waste / Debris Management shall be furnished before starting demolition of existing structures or construction work.
- 48 That the registered Private Pest Control Agency for providing anti larval treatment at the construction site shall be appointed.
- 49 That the status of road shall be submitted from A.E. (Maintenance) G/North ward before C.C.
- 50 That the application to T.P. department shall not be made by owner / developer for correction in plot area in their record book before C.C.
- 51 That the Regd. Undertaking for handing over of excess parking to BMC shall be submitted before C.C.
- 52 That the compound wall is constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per Regn. 37(24) of DCPR 2034.
- 53 That the Registered Undertaking from Owner/developer to purpose of compliance of parking only shall not be submitted.
- 54 That remarks from E.E.(M.& E.) for ventilation of basement shall not be submitted.
- 55 That the Registered Undertaking from Owner/developer to not to misuse chajja shall not be submitted.
- 56 That the feasibility of providing the basement from Geologist on the plot under reference shall not be submitted.
- 57 That following N.O.C. shall not be submitted before asking for C.C.: i) N.O.C. from B.E.S.T ii) PCO charges iii) RWH iv) revised Parking N.O.C. v) N.O.C. from Tree Authority/ Consultant shall not be submitted before asking for plinth C.C.
- 58 That the joint demarcation of T.P. shall not be submitted before asking for plinth C.C.

59 That the fresh Tax Clearance Certificate from A.A.& C. 'G/North' Ward shall not be submitted.

C: CONDITIONS TO BE COMPLIED BEFORE FURTHER C.C


- 1 That the plinth dimensions/ height shall be got checked from this office before asking for further C.C. beyond plinth.
- 2 That the Structural stability certificate through Regd. Structural Engineer regarding stability of constructed plinth shall be submitted before asking for C.C. beyond plinth.
- 3 That the amended remarks of concerned authorities / empanelled consultants for the approved plan if differing from the plans submitted for remarks, shall be submitted for: a) S.W.D. b) Parking; c) PCO; d) Sewerage; e) Water Work; f) Fire Fighting Provisions C.F.O.; g) Mechanical Ventilation; h) Tree authority; i) Hydraulic Engineer; j) NOC from electric supply company.
- 4 That the additional development cess shall not be paid before Further C.C.
- 5 That every year before onset of the monsoon / revalidation of C.C., structural stability certificate of the work executed on site shall not be submitted by the appointed Registered Structural Engineer / Consultant, appointed by owner / occupier / society.
- 6 That the Material testing report shall not be submitted.
- 7 That the yearly progress report of the work shall not be submitted by the Architect.
- 8 All the payments as intimated by various departments of MCGM shall not be paid.
- 9 That the NOC from M.B.R & R. Board for further CC shall not be submitted.
- 10 That N.O.C. from Civil Aviation Department will not be obtained for the proposed height of the building.

D: GENERAL CONDITIONS TO BE COMPLIED BEFORE O.C

- 1 That some of the drains will not be laid internally with C.I. Pipes.
- 2 That the surface drainage arrangement will not be made in consultation with E.E.(SWD) or as per his remarks or Consultant and a completion certificate will not be obtained and submitted before applying for occupation certificate / B.C.C.
- 3 That paved pathway upto staircase will not be provided.
- 4 That the surrounding open spaces, parking spaces and terrace will not be kept open and un-built upon and will not be leveled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
- 5 That the name plate/Board showing Plot No., Name of the Building etc. will not be displayed at a prominent place.
- 6 That the dry & wet waste garbage shall not be separated and the wet garbage generated in the building shall not be treated separately on the same plot by the residents / occupants of the building jurisdiction of MCGM. The necessary condition in the Sale Agreement to the effect shall not be incorporated by the Owner / Developer.
- 7 That the parking spaces shall not be provided as per Regn. 44 of DCPR 2034.
- 8 That I.O.D. and debris deposit etc. will not be claimed for refund within a period of 6 years from the date of its payment.

- 9 That Final N.O.C. shall not be submitted before issue of O.C./ B.C.C.: 1. N.O.C. from Inspector of Lifts, P.W.D., Maharashtra, will not be obtained and submitted to this office. 2. N.O.C. from C.F.O.; 3. N.O.C. from Tree Authority and from empanelled consultant for tree authority; 4. N.O.C. from H.E. Department; 5. N.O.C. from A.E. (Maint.) for Carriageway Entrance Completion.
- 10 That the Drainage completion certificate from (S.P.)(P&D) City for provision of Septic Tank / Soak pit will not be submitted to this office.
- 11 That every part of the building construction and more particularly overhead tank will not be provided as with the proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
- 12 That the Vermiculture bins for the disposal of wet waste as per design and specifications of organization or companies specialized in this field as per list furnished by Solid waste Management of M.C.G.M. shall not be provided.
- 13 That the completion certificate from the Rain Water Harvesting consultant for effective completion and functioning of RWH system shall not be submitted and quantum of rain water harvested from the RWH completed scheme on site shall not be uploaded on RWH tab in online AutoDCR system.
- 14 That the additional development cess shall not be paid before O.C.
- 15 That the following documents shall not be compiled, preserved and handed over to the end user / prospective society within a period of 30 days in case of redevelopment of properties and in other cases, the same should be handed over within a period of 90 days after granting occupation certificate by M.C.G.M.: 1. Ownership documents; 2. Copies of I.O.D., C.C., subsequent amendments, O.C.C., B.C.C. and corresponding canvass mounted plans; 3. Copies of soil investigation reports; 4. R.C.C. details and canvass mounted structural drawings; 5. Structural Stability Certificate from Licensed Structural Engineer; 6. Structural Audit Reports; 7. All details of repairs carried out in the buildings; 8. Supervision certificate issued by the Licensed Site Supervisor; 9. Building Completion Certificate issued by Licensed Surveyor/ Architect; 10. NOC and completion certificate issued by the C.F.O.; 11) Fire safety audit carried out as per the requirement of C.F.O.
- 16 The registered undertaking and indemnity bond shall not be submitted stating that the conditions mentioned at Sr. No. 15 above, will be incorporated in the sale agreement and the same will be informed to the prospective society/ end user.
- 17 That the structural drawings from R.C.C. Consultant for driveway proposed above Flushing / domestic & firefighting U.G. water tanks and pump room shall not be submitted and structural stability from R.C.C. Consultant for driveway shall not be submitted before completion of driveway or O.C. / B.C.C.
- 18 That the structural stability for stack parking from vendor and for R.C.C. Structure from Regd. Structural Engineer shall not be submitted.
- 19 That terraces, sanitary blocks, nahanis in kitchen will not be made Water proof and same will not be provided by method of pounding and all sanitary connections will not be leak proof and smoke test will not be done in presence of licensed plumber
- 20 That Notice of Completion of work u/sec. 353A of M.M.C. Act for work completed on site.
- 21 That Site Supervisor certificate for quality of work and completion of the work shall not be submitted in prescribed format.
- 22 That the Drainage Completion Certificate from Consultant from Licensed Plumber for House drain will not be submitted.

- 23 That the fresh P.R.C. in the name of the present owner shall not be submitted.
- 24 That the dust-bin will not be provided as per C.E.'s Circular No. CE/9297/II of 26-6-1978.
- 25 That the certified copy of sale agreement incorporating the following conditions shall not be submitted to this office that the prospective society / end user shall not preserve and maintain the documents / plans received from Owner / Developer / Architect and subsequently carry out necessary repairs / structural audit/ fire audit at regular interval and also present periodical structural audit reports and repair history, similarly to check and to carry out fire safety audit time to time as per requirement of C.F.O. through the authorized agency of M.C.G.M.
- 26 That the NOC from M.B.R & R. Board for OC shall not be submitted.
- 27 That the low lying plot will not be filled up to a reduced level of at least 27.55 M. Town Hall Datum or 0.15 m above adjoining road level whichever is higher with murum, earth, boulders etc. and will not be leveled, rolled, consolidated and sloped towards road side.
- 28 That the fresh Tax Clearance Certificate from A.A. & C. 'G-North' Ward shall not be submitted.
- 29 That the separte P R Cards are not submitted for the subdivided plots
- 30 That the fitness centre shall not be handed over to the end user /prospective society within a period of 30 days in case of redevelopment of properties and in other cases, the same should be handed over within a period of 90 days after granting occupation certificate by M.C.G.M.
- 31 That the structural drawings from R.C.C. Consultant for 6.00 mtr wide driveway proposed above Flushing / domestic & firefighting U.G. water tanks and pump room shall not be submitted and structural stability from R.C.C. Consultant for driveway shall not be submitted before completion of driveway or O.C. / B.C.C.
- 32 That the variation in TPS from the TP Department shall not be submitted .
- 33 That the terrace level and topmost level of the Building shall not be certified from the registered surveyor before OCC



- () That proper gutters and down pipes are not intended to be put to prevent water dropping from the leaves of the roof on the public street.
- () That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the 6 August day of 2027 but not so as to contravene any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time In force.

Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

**Executive Engineer, Building Proposals,
Zone, Wards.**

SPECIAL INSTRUCTIONS

1. THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.

2. Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 346 of the said Act.

3. Under Byelaw, No. 8 of the Commissioner has fixed the following levels :-

"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be-

- a) Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street
- b) Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.)-of such building.
- c) Not less than 92 ft. ([!TownHall]) above Town Hall Datum.

4. Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.

5. Your attention is further drawn to the provision of Section 353-A about the necessary of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance under Section 471 if necessary.

6. Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.


7. One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

8. Necessary permission for Non-agricultural use of the land shall be obtained from the Collector Mumbai Suburban District

No. P-20986/2024)/G/North/FP/IOD/1/New Dated- 07 August 2026

before the work is started. The Non-agricultural assessment shall be paid at the site that may be fixed by the Collector, under the Land Revenue Code and Rules there under.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.



No. EB/CE/ /BS /A/

NOTES

- 1) The work should not be started unless objections are complied with
- 2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
- 3) Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.
- 4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- 5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the road side drain.
- 6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presume that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.
- 7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or public street by the owner/ architect /their contractors, etc without obtaining prior permission from the Ward Officer of the area.
- 8) The work should not be started unless the manner in obviating all the objection is approved by this department.
- 9) No work should be started unless the structural design is approved.
- 10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- 11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.

- 12) All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.
- 13) No Building /Drainage Completion Certificate will be accepted non water connection granted (except for the construction purpose) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.
- 14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- 15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphaltting lighting and drainage before submission of the Building Completion Certificate.
- 16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.
- 17) The surrounding open spaces around the building should be consolidated in Concrete having broke glass pieces at the rate of 12.5 cubic meters per 10 sq. meters below payment.
- 18) The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
- 19) No work should be started unless the existing structures proposed to be demolished are demolished.
- 20) The Intimation of Disapproval is given exclusively for the purpose of enabling you to proceeds further with the arrangements of obtaining No Objection Certificate from the Housing Commissioner under Section 13 (h) (H) of the Rent Act and in the event f your proceeding with the work either without an intimation about commencing the work under Section 347(1) (aa) or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act 1966, (12 of the Town Planning Act), will be with drawn.
- 21) If it is proposed to demolish the existing structures be negotiations with the tenant, under the circumstances, the work as per approved plans should not be taken up in hand unless the City Engineer is satisfied with the following:-
 - i. Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the areas in occupation of each.
 - ii. Specifically signed agreement between you and the existing tenants that they are willing to avail or the alternative accommodation in the proposed structure at standard rent.
 - iii. Plans showing the phased programme of constructions has to be duly approved by this office before starting the work so as not to contravene at any stage of construction, the Development control Rules regarding open spaces, light and ventilation of existing structure.


- 22) In case of extension to existing building, blocking of existing windows of rooms deriving light and its from other sides should be done first starting the work.
- 23) In case of additional floor no work should be start or during monsoon which will same arise water leakage and consequent nuisance to the tenants staying on the floor below.
- 24) The bottom of the over head storage work above the finished level of the terrace shall not be less than 1.20 Mt.and not more than 1.80 mt.
- 25) The work should not be started above first floor level unless the No Objection Certificate from the Civil Aviation Authorities, where necessary is obtained.
- 26) It is to be understood that the foundations must be excavated down to hard soil.
- 27) The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
- 28) The water arrangement nut be carried out in strict accordance with the Municipal requirements.
- 29) No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai, as required in Section 381-A of the Municipal Corporation Act.
- 30) All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbet pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfections each not exceeding 1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible be providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.
- 31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
- 32) a Louvres should be provided as required by Bye0law No. 5 (b)
b Lintels or Arches should be provided over Door and Windows opening
c The drains should be laid as require under Section 234-1(a)
d The inspection chamber should be plastered inside and outside.
- 33) If the proposed additional is intended to be carried out on old foundations and structures, you will do so as your own risk.

No. P-20986/2024)/G/North/FP/IOD/1/New Dated- 07 August 2026

Executive Engineer, Building Proposals
Zones wards.

P-20986/2024)/G/North/FP/IOD/1/New

- Copy To :-
1. PANDURANG NARAYAN BHOBE
A-4, Ramesh Ghar, 223/A, T.H.Kataria Marg, Mahim, Mumbai 400 016.
 2. Asst. Commissioner G/North.
 3. A.E.W.W. G/North,
 4. Dy.A & C. City
 5. Chief Officer, M.B.R. & R. Board G/North .
 6. Designated Officer, Asstt. Engg. (B. & F.) G/North ,
 7. The Collector of Mumbai



Digitally signed by ROSHAN BHALCHANDRA BHOIR
Date: 07 Aug 2026 12:32:41
Organization : Brihanmumbai Municipal Corporation
Designation :Executive Engineer